



CITY OF KNOXVILLE FIRE DEPARTMENT
FIRE MARSHAL'S OFFICE
400 MAIN STREET SUITE 539
KNOXVILLE, TENNESSEE 37902
PHONE (865) 215-2283 FAX(865) 215-4249

FIRE CODE INSPECTION REPORT

June 1, 2016

THE FRENCH MARKET
530 S GAY ST, SUITE 102
KNOXVILLE, TN 37902

An inspection of your facility on Jun 1, 2016 revealed the violations listed below.

If you fail to comply with this notice you may be liable for the penalties provided for by law for such violations.

Violations

2012 IFC International Fire Code

Note Routine inspection with Allen Tate.

1. Remove all extension cords. Power strips may be used.
2. Lower all storage to 18 inches from ceiling.
3. Front door double keyed lock must have signage and lock identification as discussed or change to thumb turn.
4. Rear exit not required, cover exit sign or remove.
5. Areas in front of electrical panels must stay clear at all times, remove clothes.
6. Will return in 3 weeks.

000259 Donald Partin
Inspector

No Agent